



Field Installation Report

Date :- 21.06.2024		Report No. SI/FIR/24-25/123	
Customer Name :-		Equipment Attended	
HEAD District, Implementation Unit (SMART) ATMA, Bhandara		<input type="checkbox"/> Chiller <input type="checkbox"/> AHU <input type="checkbox"/> FCU <input type="checkbox"/> CT	
		<input checked="" type="checkbox"/> SAC <input type="checkbox"/> CASS <input type="checkbox"/> WIC <input type="checkbox"/> PAC	
		<input type="checkbox"/> DF <input type="checkbox"/> WC <input type="checkbox"/> IM <input type="checkbox"/> WC	
		<input type="checkbox"/> BWD <input type="checkbox"/> Visicooler <input type="checkbox"/> BMC <input type="checkbox"/> CR	
		<input type="checkbox"/> DAC <input checked="" type="checkbox"/> ODU	
		Other's (PL Specify).....	
Address :-			
Behind Gurjar Gas Godown, Rajiv Gandhi Chouk, Bhandara - 441904		Model No. :- BO-IC518RNU Serial No:- LWA18535 Model No. :- BO-IC524DNUR Serial No:- BXV09555 Model No. :- BO-IC524DNUR Serial No:- CXV12593	
Contact Person :-	Mr. Shantilal Gaidhane		
Mobile :-	9823064663	Call Ticket No. :-	N/A
Email :-	bhandara.diu.smart@gmail.com	Call Received By :-	N/A
		Call Received on :-	N/A
Delaer Code :-		Work Start on :-	20/06/2024
Blue Star Office Code :-		Work Completed on :-	21/06/2024
Obligation	Warranty		
	1 Year from the Date of Installation	Test Measurements (as applicable)	
Fault / Defect Code	Description	Voltage	230
	Installation	PSIG Suction pr.	
		PSIG Discharge pr.	
		Compressor Amps	
		Canvas / Grill temp	10°C
Action taken Code	Description	Return Air temp	
	Installation Done 3 Nos. Air Conditioning Work Completed All work Properly.	Ambient temp	28°C
		Room temp	
		Chiller Water Inlet	N/A
		Chiller Water Outlet	N/A
Follow up action (if any)	Add Material Used	Material Used	
N/A	Wall Stand 6 Nos.	Copper Pipe Unit No.1, 2 & 3.	100 Rft
		Communication Cable Unit 1, 2 & 3.	100 Rft
		Drain Pipe for Unit 1, 2 & 3.	40 Rft
		Mounting Stand	03 Nos
		4 Core Power Cable Unit 1, 2 & 3.	35 Rmt
		3 Core Control Cable Unit 1, 2 & 3.	25 Rmt
		½ mm Earthing Cabel	10 Rmt
		25 Amp MCB	03 Nos
		¾ Way MCB Box	01 Nos
		16 A Five pin socket	03 Nos
		Power Plug	03 Nos
		Black Screw 25X6mm & 36X6mm	24 Nos
		PVC 25mm Cable Clip	60 Nos
Insulation Tape	03 Nos		
Customer's Signature & Company's Seal		Call attended by Sign. Mr. Krunal Bhure	
		 Proprietor	